



# Yuma County Department of Engineering

**TO:** All Known Contractors, Plan Holders, & Other Interested Parties  
**FROM:** Dave Wostenberg, P.E., Project Manager  
**SUBJECT:** Addendum No. 2  
**PROJECT:** Avenue A & County 15<sup>th</sup> St, CIP 1.9915E  
**DATE:** August 26, 2020

---

Schedule for bid opening is on *August 27, 2020* at 1:30 p.m. (MST)

In accordance with the Project Specifications and Contract Documents, Bidders on the above referenced Project are hereby notified that this Addendum shall be made a part of the Project Specifications and Contract Documents and the Bidder shall acknowledge receipt on Page PK1 of the Proposal Pamphlet.

**Question #1:** The specifications and plans call for 36-inch C-905 DR18 This would mean that the pipe is high pressure. Is this type of pipe really necessary as the irrigation district usually uses DR35.

**Answer #1:** DR18 is required due to the amount of cover during and after construction. Both District and the Bureau of Reclamation have signed off based on the minimal cover and the class of pipe called out.

**Question #2:** The specifications call the 36-inch C-905 DR18 pipe to be purple in color or have a purple sleeve. Is this color of pipe really necessary as the irrigation district usually uses green PVC pipe.

**Answer #2:** The County will modify the specs to remove the color requirement.

**Remove the following from Section 504.2:**

*The pipe shall either be purple in color to denote that it is a non-potable irrigation water line (preferred), or shall be installed inside a purple inert polyethylene plastic sleeve per MAG Section 616.4 (Identification).*

No further questions will be accepted and no further addendums will be issued.

